

REQUEST FOR COUNCIL ACTION

MEETING

DATE: 2/19/03

53

AGENDA SECTION: CONSENT AGENDA	ORIGINATING DEPT: Public Works	ITEM NO. D-20
ITEM DESCRIPTION: Supplemental Agreement #1, #2 and #3 Sanitary Sewer and Watermain to Serve Rose Harbor Subdivision, J9749		PREPARED BY: J. Loehr

The City previously entered into a contract with Road Constructors, Inc. for the construction of sanitary sewer and watermain to serve Rose Harbor Subdivision in a project described as follows:

Project No. M1-05, J9749

"Sanitary Sewer Extension to Serve the Rose Harbor Subdivision Area and Public Improvements to Serve Undeveloped Property Located in the Rose Harbor Subdivision Area."

SA #1: The plan and specification require the extension of sanitary sewer, watermain and storm sewer from previously installed sanitary sewer, watermain and storm sewer that are located at the west end of Knollwood Drive SE. The horizontal and vertical alignment of the previously installed utilities does not allow the extension of the utilities at the plan alignments and elevations. Public Works determined that portions of the previously installed utilities needed to be removed to allow for the extension of the utilities at the plan alignment and elevations. Public Works negotiated an amount of \$3,805.75 as compensation to Road Constructors for this work.

SA #2: The plan and specification provide for the sanitary sewer manhole no. 34 at the intersection of Eastwood Road and Harbor Drive SE. Future development of undeveloped land located east of Rose Harbor requires sewer service from manhole no. 34. The plan and specification does not provide for a sanitary sewer extension to the east. Public Works determined that manhole no. 34 should be modified provide for a sewer main extension to the east from the manhole. Public Works negotiated an amount of \$1,314.17 as compensation to Road Constructors for this modified manhole.

SA #3: The plan and specification provide for the extension of 12" watermain easterly from the intersection of Eastwood Road and Harbor Drive SE to a previously installed 12" watermain. The previously installed 12" watermain was incorrectly shown on the plan. Extra work was required to install and connect the 12" watermain to the previously installed 12" watermain. Public Works determined that it is necessary to perform the extra work to meet the intent of the plan and specification. Public Works negotiated an amount of \$2,300.00 as compensation to Road Constructors for this extra work.

COUNCIL ACTION REQUESTED:

1. Adopt a resolution authorizing payment of SA #1 in the amount of \$3,805.75.
2. Adopt a resolution authorizing payment of SA #2 in the amount of \$1,314.17.
3. Adopt a resolution authorizing payment of SA #3 in the amount of \$2,300.00

Attachments: Supplemental Agreement #1, #2 and #3

COUNCIL ACTION: Motion by: _____ Second by: _____ to: _____

54